5.5.4 Thermal Distribution Equipment Design Load and Electricity Intensities, by System Type

| | Design Load Intensity (W/SF) | | | End Use Intensity (kWh/SF) | | |
|----------------------|------------------------------|-------------|--------------|----------------------------|-------------|--------------|
| | Central VAV | Central CAV | Packaged CAV | Central VAV | Central CAV | Packaged CAV |
| Condenser Fan | | | 0.3 | | | 0.2 |
| Cooling Tower Fan | 0.2 | 0.2 | | 0.1 | 0.2 | 0.0 |
| Condenser Water Pump | 0.2 | 0.2 | | 0.3 | 0.3 | 0.0 |
| Chilled Water Pump | 0.2 | 0.2 | | 0.1 | 0.2 | 0.0 |
| Supply & Return Fans | 0.7 | 0.5 | 0.6 | 1.2 | 1.9 | 1.9 |
| Chiller/Compressor | 1.9 | 1.8 | 3.3 | 1.7 | 2.3 | 4.0 |

Source(s): BTS/A.D. Little, Energy Consumption Characteristics of Commercial Building HVAC Systems, Volume II: Thermal Distribution, Auxiliary Equipment, and Ventilation, Oct. 1999, Table 5-11 p. 5-22.